

Non-Network Options Report SSLGV

4 August 2020

Version 1.0

Logan Village Zone Substation Limitation

Consultation Period Starts: 10/08/2020

Consultation Period Closes: 20/11/2020



Part of the Energy Queensland Group

Disclaimer

While care was taken in preparation of the information in this Non-Network Options Report, and it is provided in good faith, Energex Limited accepts no responsibility or liability for any loss or damage that may be incurred by any person acting in reliance on this information or assumptions drawn from it. This document has been prepared for the purpose of inviting information, comment and discussion from interested parties. The document has been prepared using information provided by a number of third parties. It contains assumptions regarding, among other things, economic growth and load forecasts which may or may not prove to be correct. All information should be independently verified to the extent possible before assessing any investment proposal.

Non-Network Options Report



EXECUTIVE SUMMARY

ABOUT ENERGEX

Energex is a subsidiary of Energy Queensland Limited, a Queensland Government Owned Corporation. Energex distributes electricity to over 1.5 million residential, commercial and industrial customers across a population base of around 3.4 million in South East Queensland.

IDENTIFIED NEED

Logan Village zone substation (SSLGV) is supplied from Jimboomba bulk supply substation (SSJBB BSP) via a single 33kV radial feeder, F470. There is backup 33kV radial supply from Beenleigh bulk supply substation (SST108), F3620. SSLGV provides electricity supply to approximately 4,400 predominately domestic customers in the Yarrabilba, Buccan, Chambers Flat, Logan Village, Logan Reserve, Park Ridge, Park Ridge South and Waterford area. The Yarrabilba development on the south of SSLGV when fully developed is anticipated to provide approximately 20,000 dwellings to house a population of up to 50,000 people with an ultimate forecast of up to 86MVA load to the network.

The identified need for this Non-Network Options Report (NNOR) is that Energex will not meet its Safety Net obligation as outlined in its Distribution Authority at SSLGV in the summer of 2020/21 due to load growth in the area. In order to eliminate the load at risk and satisfy the Safety Net obligations, Energex has identified several network options to address the limitations identified:

- Option 1: Install 2nd 33/11kV transformer and associated modular switchgear at SSLGV.
- Option 2: Establish a new 25MVA 33/11kV modular substation Yarrabilba North (356).
- Option 3: Upgrade Jimboomba zone substation by installing a 3rd 33/11kV, transformer and associated modular switchgear.

The requirements of a non-network option to solve the identified need are summarised in Table 1.

| Customer Category | Total Limit | Year | Forecast 50 PoE Load (MVA) | Load at risk (MVA) | Days over limit | % Time Above Limit | Hours |
|-------------------|-------------|------|----------------------------|--------------------|-----------------|--------------------|-------|
| Rural | 15.2MVA | 2021 | 19.8 | 4.6 | 13 | 0.45% | 39 |
| | | 2022 | 18.4 | 3.2 | 7 | 0.23% | 20.5 |
| | | 2023 | 18.9 | 3.7 | 8 | 0.29% | 25.5 |
| | | 2024 | 19.2 | 4.0 | 9 | 0.33% | 29 |
| | | 2025 | 19.5 | 4.3 | 10 | 0.37% | 32.5 |
| | | 2026 | 19.8 | 4.6 | 13 | 0.45% | 39 |
| | | 2027 | 20.1 | 4.9 | 15 | 0.53% | 46.5 |
| | | 2028 | 20.6 | 5.4 | 22 | 0.71% | 62.5 |
| | | 2029 | 21.1 | 5.9 | 25 | 0.86% | 75 |

Table 1: Non-network Option Requirements for SSLGV

Non-Network Options Report



APPROACH

The National Electricity Rules (NER) require that, subject to certain exclusion criteria, network business investments for meeting service standards for a distribution business are subject to a Regulatory Investment Test for Distribution (RIT-D). Energex has determined that network investment is essential in this case for it to continue to provide electricity to the consumers in the Logan Village and Yarrabilba areas in a reliable, safe and cost-effective manner and meet its obligations under its Distribution Authority. Accordingly, this investment is subject to a RIT-D. This non-network options report has been prepared by Energex in accordance with the requirements of clause 5.17.4(e) of the NER and seeks information from interested parties about possible alternate solutions to address the need for investment.

Submissions in writing (electronic preferably) are due by 20 November 2020 by 4:00 PM. For further information on this or to enquiry further, please refer to section 1.2.

Non-Network Options Report



CONTENTS

| | | |
|--------|--|----|
| 1. | Introduction | 1 |
| 1.1. | General Terms and Conditions | 1 |
| 1.2. | Contact Details | 1 |
| 2. | Background | 2 |
| 2.1. | Existing Network | 2 |
| 2.2. | Load Profiles | 4 |
| 3. | Identified Need | 5 |
| 3.1. | Applied Service Standards | 5 |
| 3.2. | Description of the Identified Need | 6 |
| 3.2.1. | Safety Net Non-Compliance | 6 |
| 3.3. | Quantification of the Identified Need | 6 |
| 3.3.1. | Safety Net Non-Compliance | 6 |
| 4. | Assessment Methodology & Assumptions | 10 |
| 4.1. | Demand Forecasts | 10 |
| 4.2. | Discount Rate | 10 |
| 4.3. | Cost Estimates | 10 |
| 4.4. | Evaluation Test Period | 10 |
| 5. | Internal Options Considered | 11 |
| 5.1. | Non-Network Options Identified | 11 |
| 5.2. | Do Nothing (Base Case) | 11 |
| 5.3. | Option 1: Install 2 nd 25MVA 33/11kV Transformer and associated modular switchgear at SSLGV | 11 |
| 5.4. | Option 2: Establish new 25MVA 33/11kV Yarrabilba North zone substation | 12 |
| 5.5. | Option 3: Upgrade Jimboomba Zone Substation | 13 |
| 5.6. | Preferred Network Option | 14 |
| 5.7. | Potential Deferred Augmentation Charge | 14 |
| 6. | Non-Network Options | 15 |

Non-Network Options Report



| | | |
|--------------------------------------|--|----|
| 6.1. | Assessment of Non-Network Solutions..... | 15 |
| 6.2. | Feasible vs Non-Feasible Options..... | 15 |
| 6.2.1. | Potentially Feasible Options | 15 |
| 6.2.2. | Options That Are Unlikely To Be Feasible | 15 |
| 6.2.3. | Timing of Feasible Options..... | 16 |
| 7. | Submission Steps | 17 |
| 7.1. | Submission from Proponents | 17 |
| 7.2. | Next Steps | 18 |
| 8. | Compliance Statement | 19 |
| Appendix A – The RIT-D Process | | 20 |
| Appendix B – Glossary of Terms..... | | 21 |

1. Introduction

This document is a Non-Network Options Report (NNOR) requesting stakeholders' submissions for credible options to address the identified need in the network. This report is the first stage of the consultation process in the application of the Regulatory Investment Test for Distribution (RIT-D) on credible options to address the identified need for this study area.

The report includes background information about the limitations in this area, highlights the identified need, outlines credible network options, provides the requirements that a non-network proponent would need to meet and specifies the process for interested stakeholder submissions.

1.1. General Terms and Conditions

1. By issuing this Non-Network Options Report (NNOR), Energex is under no obligation whatsoever to review, discuss, select or enter into any agreement with any proponent who may submit a proposal.
2. Proponents will be responsible for all costs associated with the preparation and assessment of providing a proposal in response to this NNOR including but not limited to any site visits and responding to further information requests made by Energex in order to assist Energex in its assessment of the proposal.
3. When evaluating a proposal, Energex will act in accordance with the NER and RIT-D Guidelines (available on the Australian Energy Regulator (AER) website). Further, Energex will follow the process as described in Energex's Demand Side Engagement Strategy (DSES) a copy of which can be found [here](#).
4. Energex may combine all or parts of separate proposals for the purposes of evaluation where this may lead to a more efficient outcome than the separate proposal or option. Proponents should indicate in their proposal whether they wish to have their proposals or options considered in isolation or in combination with other proponents' proposals.
5. Energex will publicly announce the outcome of the evaluation process. This announcement will be published on Energex's website and unless otherwise agreed in writing at the commencement of the assessment process all details of proposals including cost information will be treated as public information.

1.2. Contact Details

Submissions in writing in response to this report may be submitted to demandmanagement@energex.com.au and are due by 20 November 2020

2. Background

2.1. Existing Network

Logan Village zone substation (SSLGV) provides electricity supply to approximately 4,400 predominately domestic customers in the Yarrabilba, Buccan, Chambers Flat, Logan Village, Logan Reserve, Park Ridge, Park Ridge South and Waterford area.

SSLGV is supplied from Jimboomba bulk supply substation (SSJBB) via a single 33kV feeder, F470, under system normal conditions. Following an outage of F470, an auto-changeover scheme (ACO) operates such that SSLGV is supplied via 33kV feeder F3620 from Beenleigh bulk supply substation (SST108). Geographic and schematic views of the network area under study are provided in Figure 1, Figure 2 and Figure 3.




Figure 1: Existing sub-transmission network arrangement (Geographic view)

Non-Network Options Report




Figure 2: Existing 11kV network arrangement (Geographic view)




Figure 3: Existing Network Arrangement (Schematic View)

2.2. Load Profiles

The annual load profile for SSLGV is shown in Figure 4 below.





Figure 4: Annual Load Profile (MVA) for SSLGV

Figure 5 shows the load duration curve for SSLGV. This is based on the previous 3 years of data and is scaled to its 50% Probability of Exceedance (50PoE) forecast.



*The values for SSLGV have been scaled to the 2021 peak forecast load of 19.8MVA

Figure 5: Load duration curve for SSLGV

3. Identified Need

3.1. Applied Service Standards

Under its Distribution Authority, Energex must adhere to the Safety Net which identifies the principles that apply to the operation of network assets under network contingency conditions. System contingency related capability is assessed against a 50% probability of exceedance (PoE) forecast load, available load transfers, emergency cyclic capacity (ECC) ratings, non-network response, mobile plant, mobile generators, and short-term ratings of plant and equipment where available. This process allows load at risk under system normal and contingency conditions to be identified and assessed. Energex's Distribution Authority can be accessed by the following link:

https://www.dnrme.qld.gov.au/_data/assets/pdf_file/0003/219486/distribution-authority-d0798-energex.pdf

SSLGV is classified as a Rural zone substation, and as such, the following Safety Net criteria apply:

- For a rural zone substation, during a single contingency event, interruption of supply up to 40MVA is permissible for the first 30 minutes, followed by a maximum of interruption of up to 15MVA is permissible, provided all load except for up to 10MVA can be restored within 4 hours, and the remaining load fully restored within 12 hours.

Table 2 below outlines the Safety Net criteria.

| Category | Demand Range | Allowed Outage to be OK |
|----------|--------------|-------------------------|
| Rural | >40MVA | No outage OK |
| | 15-40MVA | 30 minutes OK |
| | 10-15MVA | 4 hours OK |
| | <10MVA | 12 hours OK |

Table 2: Summary of Safety Net Criteria

Further to an assessment against its Safety Net obligations, Energex also undertake analysis of system capacity under normal conditions with all plant in service against the 10PoE load.

3.2. Description of the Identified Need

3.2.1. Safety Net Non-Compliance

The existing supply to the Logan Village and Yarrabilba areas does not meet the Safety Net for an unplanned outage of a transformer at SSLGV. The following section outlines the substation and feeder limitations of the existing network. The system normal condition is assessed against the 10%PoE load forecast for SSJBB bulk supply substation and SSLGV and SSJBB zone substations. The 50%POE load forecast is used for N-1 contingency analysis.

3.3. Quantification of the Identified Need

3.3.1. Safety Net Non-Compliance

SSLGV Limitations

SSLGV is equipped with 1 x 25MVA 33/11kV transformer. The substation capacity is limited by transformer itself and provides an NCC, ECC and 2HEC as below:

- NCC – 30MVA
- ECC – 0MVA
- 2HEC – 0MVA

Figure 6 shows the network limitations at SSLGV. Note that there are permanent load transfers from SSLGV to SSJBB and from SSLGV to Crestmead zone substation (SSCRM) which results in a slight reduction in load between 2020/21 and 2021/22.





Figure 6: Load Forecast and Load at Risk for SSLGV

Figure 6 above illustrates that there is Safety Net load at risk associated with an outage of TR1 at SSLGV, increasing from 4.61MVA to 6.42MVA.

To meet Energex's Safety Net obligations, SSLGV can supply up to 15.2MVA. This incorporates 5.2MVA of available load transfers and 10MVA of mobile generation support. Figure 7 shows the portion of the load duration curve for the forecast 11kV load of SSLGV and available capacity at SSLGV.



*The values for SSLGV have been scaled to the 2021 peak forecast load of 19.81MVA.

Figure 7: Load Duration Curve SSLGV

Figure 7 shows that approximately 0.45% of the time in 2020/21 the load is above the 15.2MVA limit.

Non-Network Options Report



Figure 8 shows that as the load increases each year, the limit is surpassed for a longer duration per year. For ease of presentation, only every second year is shown.




Figure 8: Load duration curve for 2021 - 2029

Figure 8 above shows that the duration in which the load is at risk rises from 0.45% to 0.86% of the year.

Table 3 illustrates that the amount of time support would be required is forecast to start with 13 days in 2020/21 and increases significantly to 25 days by 2028/29.

| Customer Category | Total Limit | Year | Forecast 50 PoE Load (MVA) | Load at risk (MVA) | Days over limit | % Time Above Limit | Hours |
|-------------------|-------------|------|----------------------------|--------------------|-----------------|--------------------|-------|
| Rural | 15.2MVA | 2021 | 19.8 | 4.6 | 13 | 0.45% | 39 |
| | | 2022 | 18.4 | 3.2 | 7 | 0.23% | 20.5 |
| | | 2023 | 18.9 | 3.7 | 8 | 0.29% | 25.5 |
| | | 2024 | 19.2 | 4.0 | 9 | 0.33% | 29 |
| | | 2025 | 19.5 | 4.3 | 10 | 0.37% | 32.5 |
| | | 2026 | 19.8 | 4.6 | 13 | 0.45% | 39 |
| | | 2027 | 20.1 | 4.9 | 15 | 0.53% | 46.5 |
| | | 2028 | 20.6 | 5.4 | 22 | 0.71% | 62.5 |
| | | 2029 | 21.1 | 5.9 | 25 | 0.86% | 75 |

Table 3: Forecast duration load will be at risk

SSJBB Zone Substation

SSJBB is equipped with 1 x 15MVA and 1x 25MVA 33/11kV transformers. The substation capacity is limited by the 15MVA transformer and provides an NCC, ECC and 2HEC as below:

- NCC – 48MVA
- ECC – 20.25MVA
- 2HEC – 21.7MVA

Figure 9 shows the limitations at SSJBB:




Figure 9: Load Forecast and Load at Risk for SSJBB

Figure 9 shows a network limitation at SSJBB in 2027/28 of 0.5MVA, increasing to 2.73MVA in 2029/30. It should be noted that SSJBB is currently sharing the load growth from the Yarrabilba development area with SSLGV. It is anticipated that if either substation was upgraded to supply load in this area, that substation would see most of the load growth.

4. Assessment Methodology & Assumptions

4.1. Demand Forecasts

Please refer to Section 5 (Network Forecasting) of the latest Energex DAPR publication for in-depth details regarding the methods and assumptions behind Energex's demand forecasts.

4.2. Discount Rate

Calculations for annual deferral values of projects are based on Energex's regulated pre-tax real Weighted Average Cost of Capital (WACC). This value is prescribed by the AER for a specific regulatory control period. The identified need described in this Non-Network Options Report occurs in the 2020-2025 regulatory control period, where the WACC is 2.62%. (Note that this is lower than the WACC in the previous regulatory control period.)

4.3. Cost Estimates

Project costs are calculated using standard estimate components which are developed & evaluated by estimation teams in Energex. The costs are split into 2 components: direct cost, which is the costs which are directly costed to the project; and indirect costs which cover overheads associated with the business. All costs provided in this report are estimated to fall within $\pm 40\%$ accuracy of the stated cost.

4.4. Evaluation Test Period

Consideration of network options is assessed over an evaluation period of 60 years.

5. Internal Options Considered

5.1. Non-Network Options Identified

No non-network options have been identified at this stage.

5.2. Do Nothing (Base Case)

The identified need is a non-compliance of the Energex's Safety Net obligations outlined in Energex's Distribution Authority. As such, the Do Nothing option is not an acceptable outcome.

5.3. Option 1: Install 2nd 25MVA 33/11kV Transformer and associated modular switchgear at SSLGV

This option involves installing a second 25MVA 33/11kV transformer and 2nd modular substation in October 2023.

The works required to implement this option are:

- Install 2nd 25MVA 33/11kV modular substation.
- Cut over existing 33kV feeder F3620 to the new modular substation.
- Cut over 2 x 11kV feeders to the new modular substation.
- Reconfigure 11kV feeders to de-load SSJBB
- Estimated capital expenditure: \$8.57 million \pm 40%
- Estimated operating expenditure: \$3,300 / annum

A schematic diagram of the proposed solution is shown in Figure 10 below.




Figure 10: Proposed Network Arrangement under Option 1

5.5. Option 3: Upgrade Jimboomba Zone Substation

This option involves upgrading Jimboomba zone supply by installing a 3rd 25MVA 33/11kV modular substation by October 2023.

The works required to implement this option are:

- Install 3rd 25MVA 33/11kV modular substation.
- Cut over the “A” (JBBTR7A) leg of TR7 to the new 3rd modular substation.
- Cut over 2 x 11kV feeders to the new 3rd modular substation.
- Reconfigure and uprate existing 11kV feeders to de-load SSLGV.
- Establish new 11kV feeders to the east with spare conduits to support future Yarrabilba development as part of distribution project.
- Split 11kV bus (BB11) supplied from TR1 and modify existing ACO scheme for the loss of TR1.
- Estimated capital expenditure: \$ 8.48million ± 40%
- Estimated operating expenditure per annum: \$7,300 / annum

This option has the disadvantage of requiring longer 11kV feeders to supply the load at Yarrabilba over both SSLGV and a new Yarrabilba zone substation. Furthermore, a second transformer and modular building is still likely to be required at a future stage under this option. A schematic diagram of the proposed solution is shown in Figure 12 below.




Figure 12: Proposed Network Arrangement under Option 3

5.6. Preferred Network Option

Option 1 is currently the preferred network option. SSLGV is closer to most of the new developments, meaning it is less costly to construct 11kV feeder to supply the new forecast loads. The scope of the preferred network option includes:

- Establish a second 33/11kV transformer
- Establish a second modular 33kV and 11kV substation building

The preferred network option has an estimated capital project cost of \$8.57M, and an annual operating cost of approximately \$3,300 / annum.

5.7. Potential Deferred Augmentation Charge

Energex have estimated the capital cost of the network options to within $\pm 40\%$ of estimation accuracy. Using these costs as a guide, a deferral of the preferred network option by a year represents a deferral saving of approximately \$230,000 per annum, assuming the same reliability outcomes are maintained as with the preferred network option. While this should not be considered as the precise deferral cost available to a non-network proponent, it serves as a guide for interested parties to determine the viability of their proposal. Energex will work with non-network proponents based on the specifics of what the proponents offer and any necessary further works that Energex may have to undertake to ensure the reliability, security and safety of the network are maintained.

6. Non-Network Options

6.1. Assessment of Non-Network Solutions

To reduce, defer or eliminate network expenditure, a non-network proponent would need to provide a non-network option that would eliminate the Load at Risk outlined in Table 3.

6.2. Feasible vs Non-Feasible Options

6.2.1. Potentially Feasible Options

The identified need presented in this Non-Network Options Report is driven by Energex not meeting its Safety Net obligations. Specifically, an outage of the existing transformer at SSLGV leads to a Safety Net load at risk of 4.6MVA in 2021/22 which increases in future years. Figure 7, Figure 8 and Table 3 in Section 3.3 outlines the load reduction and operating profile required to reduce or eliminate the Identified Need.

In respect of the requirements under 5.17.4(e)(4), any non-network option will contribute to power system security and reliability to the extent that the solution solves the Safety Net limitation. The contribution to power system fault levels is not an issue for this limitation.

Any solutions that prudently and efficiently address these constraints will be considered. A non-exhaustive list of potentially feasible options includes:

- Embedded dispatchable network generation
- Embedded energy storage systems
- Embedded energy storage systems combined with Generation (possibly dispatchable or non-dispatchable)
- Load curtailment agreements with customers to disconnect from the network following a contingency.

It should be noted that the above options may be aggregated across several substations in the network. For example, embedded solutions or load curtailment options could be implemented in the supply areas of Jimboomba and Logan Village to provide the required network support.

6.2.2. Options That Are Unlikely To Be Feasible

Without attempting to limit a potential proponent's ability to innovate, unproven, experimental or undemonstrated technologies are unlikely to be considered as feasible options to address the identified limitation.

6.2.3. Timing of Feasible Options

The limitations presented in this report are from the summer period 2021/22. Energex is currently forecasting that the preferred network option would not be constructed until October 2023. As such, any proposed option must be available by at least October 2023. Irrespective, the Safety Net non-compliance will still exist and as such Energex will still be seeking responses from interested parties who are able to provide network support to reduce or eliminate this limitation starting from 2020/21 in a cost-effective manner, for this limitation of around 4.6MVA.

7. Submission Steps

7.1. Submission from Proponents

Energex invites written submissions to address the identified need in this report from registered participants and interested parties. With reference to Section 6, all submissions should include enough technical and financial information to enable Energex to undertake comparative analysis of the proposed solutions against alternative options. The proposals should include, but are not limited to, the following:

- Full costs of completed works including delivery and installation where applicable.
- Whole of life costs include operational costs.
- Project execution strategy including design, testing and commissioning plans.
- Engineering network system studies and study reports.

Energex will not be legally bound or otherwise obligated to any person who may receive this RIT-D report or to any person who may submit a proposal. At no time will Energex be liable for any costs incurred by a proponent in the assessment of this RIT-D report, any site visits, obtainment of further information from Energex or the preparation by a proponent of a proposal to address the identified need specified in this RIT-D report.

The RIT-D process is aimed at identifying a technically feasible non-network alternative to the internal option that has greater net economic benefits. However, the selection of the solution provider to implement the preferred option will be done in accordance with Energex's standards for procurement.

Submissions in response to the report may be submitted to demandmanagement@energex.com.au and are due by **20 November 2020**.

7.2. Next Steps

Energex intends to carry out the following process to assess what action should be taken to address the identified need in the Logan Village supply area:

| | | |
|--------|---|--|
| Step 1 | Publish Non-Network Options Report (this report) inviting non-network options from interested participants | Date Released: 10 August 2020 |
| Step 2 | Submissions in response to the Non-Network Options Report | Due Date: 20 November 2020 |
| Step 3 | Review and analysis of proposals by Energex This is likely to involve further consultation with proponents and additional data may be requested. | Anticipated to be completed by: 11 December 2020 |
| Step 4 | Release of Draft Project Assessment Report (DPAR) | Anticipated to be released by: 18 December 2020 |
| Step 5 | Submissions in response to the Draft Project Assessment Report. | Due Date: 12 February 2021 |
| Step 6 | Review and analysis by Energex. This is likely to involve further consultation with proponents and additional data may be requested. | Anticipated to be completed by: 26 February 2021 |
| Step 7 | Release of Final Project Assessment Report (FPAR) including summary of submissions received | Anticipated to be released by: 5 March 2021 |

Energex will use its reasonable endeavours to maintain the consultation program listed above. However, due to changing power system conditions or other circumstances beyond the control of Energex this consultation schedule may change. Up-to-date information will be available on the Current Consultations webpage which can be accessed by the following link:

<https://www.energex.com.au/home/our-services/projects-And-maintenance/current-consultations>


During the consultation period, Energex will review, compare and analyse all internal and external solutions. At the conclusion of the consultation process, Energex will publish a final report which will detail the most feasible option. Energex will then proceed to take steps to progress the recommended solution to ensure any statutory non-compliance is addressed and undertake appropriately justified network reliability improvement, as necessary.

8. Compliance Statement

This Non-Network Options Report complies with the requirements of NER section 5.17.4(e) as demonstrated below:

| Requirement | Report Section |
|---|----------------|
| (1) a description of the identified need; | 3 |
| (2) the assumptions used in identifying the identified need (including, in the case of proposed reliability corrective action, why the RIT-D proponent considers reliability corrective action is necessary; | 3.1 |
| (3) if available, the relevant annual deferred <i>augmentation</i> charge associated with the identified need; | 5.7 |
| (4) the technical characteristics of the identified need that a non-network option would be required to deliver, such as: (i) the size of <i>load</i> reduction or additional <i>supply</i> ; (ii) location; (iii) contribution to <i>power system security</i> or <i>reliability</i> ; (iv) contribution to <i>power system</i> fault levels as determined under clause 4.6.1; and (v) the operating profile; | 6 |
| (5) a summary of potential credible options to address the identified need, as identified by the RIT-D proponent, including network options and non-network options; | 5 & 6.2 |
| (6) for each potential credible option, the RIT-D proponent must provide information, to the extent practicable, on: (i) a technical definition or characteristics of the option; (ii) the estimated construction timetable and commissioning date (where relevant); and (iii) the total indicative cost (including capital and operating costs); and | 5 |
| (7) information to assist non-network providers wishing to present alternative potential credible options including details of how to submit a non-network proposal for consideration by the RIT-D proponent. | 6 & 7.1 |

Appendix A – The RIT-D Process



Source: AEMC, *Rule determination: National Electricity Amendment (Replacement expenditure planning arrangements) Rule 2017*, July 2017, p. 64.

Appendix B – Glossary of Terms

| Term | Definition |
|---------------------------|---|
| Peak Risk Period | The time period over which the load is highest (Day/Night). |
| NCC Rating (MVA) | <p>Normal Cyclic Capacity – the total capacity with all network components and equipment in service.</p> <p>The maximum permissible peak daily loading for a given load cycle that plant can supply each day of its life. Taking impedance mismatch into consideration, it is considered the maximum rating for a transformer to be loaded under normal load conditions.</p> |
| 10 PoE Load (MVA) | Peak load forecast with 10% probability of being exceeded (one in every 10 years will be exceeded). Based on normal expected growth rates & weather corrected starting loads. |
| LARn (MVA) | Security standard load at risk under system normal condition, expressed in MVA. |
| LARn (MW) | Security standard load at risk under system normal condition, expressed in MW. |
| Power Factor at Peak Load | Compensated power factor at 50 PoE Load. Capacitive compensation is switched according to the size of the capacitor banks installed at the substation, compensation is generally limited to prevent a substation from going into leading power factor. |
| ECC Rating (MVA) | <p>Emergency Cyclic Capacity – the long term firm delivery capacity under a single contingent condition.</p> <p>The maximum permissible peak emergency loading for a given load cycle that an item of plant can supply for an extended period of time without unacceptable damage. For substations with multiple transformers, the ECC is the minimum emergency cyclic capacity of all transformer combinations taking impedance mismatches into consideration, with one transformer off-line.</p> |
| 50 PoE Load (MVA) | Peak load forecast with 50% probability of being exceeded (one in every two years will be exceeded). Based on normal expected growth rates and weather corrected starting loads. |
| Raw LAR (MVA) | <p>The amount of load exceeding ECC rating.</p> <p>(50 PoE Load – ECC Rating)</p> |
| 2-Hour Rating (MVA) | <p>Two-Hour Emergency Capacity (2HEC) – the short term or firm delivery capacity under a single contingent condition.</p> <p>The maximum permissible peak emergency loading for a given load cycle that an item of plant can supply up to two hours without causing unacceptable damage. For substations with multiple transformers, the 2HEC is the minimum two hour emergency rating of all transformer combinations taking impedance mismatches into consideration, with one transformer off line.</p> |

Non-Network Options Report



| Term | Definition |
|--------------------------|--|
| Auto Trans Avail (MVA) | SCADA or automatically controlled load transfers that can be implemented within one minute. |
| Remote Trans Avail (MVA) | Load transfers that can be implemented through SCADA switching procedures by the network control officer. It is assumed that this can generally be achieved within 30 minutes excluding complex or time –consuming restoration procedures. |
| Manual Trans Avail (MVA) | <p>Load transfers can also be deployed via manually controlled switchgear locally by field staff. It is assumed that the implementation of manual switching procedures to isolate the faulted portion of the network to restore supply to healthy parts of the network can be fully implemented within three hours (urban) or four hours (rural).</p> <p>Manual transfers are obtained from load flow studies performed on each 11kV distribution feeder based on the forecast 2016/17 load, the sum of all available 11kV transfers at a substation is multiplied by a 0.75 factor to account for diversity and to provide a margin of error to avoid voltage collapse. The same approach applies throughout the forward planning period.</p> |
| LARc (MVA) | Security standard load at risk for single contingent conditions. |
| LARc (MW) | Estimated generation / load reduction required to defer the forecast system limitation. This is the security standard load at risk for a single contingency, expressed in MW. |
| Customer Category | For security standard application, the general type of customer a substation or feeder supplying the area. |